

AHERA - ASBESTOS INSPECTION OF ACM & PACM

| |
|----------------------------------|
| HAZARD SCHOOL BUILDING |
| SOUTH KINGSTON SCHOOL DEPARTMENT |

| |
|------------------------------------|
| INSPECTION DATE: FEBRUARY 28, 2018 |
| ORIGINAL BLDGS. BUILT IN 1911 |
| COMPLETELY RENOVATED IN 1996 |

| INSPECTION FINDINGS | | | | | | | | | | | | | Initials of Surveillance Inspector | | | | | | |
|-----------------------|-------|-------------------------|-------------------------|-------------------|-------------------|-------------------|-----------------|---------|---------|------------------|----------------|----------|--|-----------------------|------|------|------|------|--|
| Location of ACBM | Floor | Type and Quantity | | | | | Response Action | | | | | | Comments / Notes | 6 MONTH SURVEILLANCES | | | | | |
| | | 12" FLOOR TILE & MASTIC | PLASTER WALLS & CEILING | GYPSUM WALL BOARD | 2' X 2' CEIL TILE | 2' X 4' CEIL TILE | ACM | FRIABLE | DAMAGED | PHYSICAL ACCESS. | HAZARD ASSESS. | RESPONSE | | 8/18 | 2/19 | 8/19 | 2/20 | 8/20 | |
| HOMOGENEOUS AREA | | MISC | SURFACE | MISC | | | | | | | | | | | | | | | |
| THROUGHOUT 2 LEVELS | 1-2 | 25,000+ S.F. | | | | | A | N | N | 5 | 2 | M8 | | N/C | N/C | N/C | | | |
| | 1-2 | | | 5,000+ S.F. | | | A | N | N | 5 | 2 | M8 | | N/C | N/C | N/C | | | |
| | 1-2 | | 15000+ | | | | A | N | N | 5 | 2 | M8 | | N/C | N/C | N/C | | | |
| | B | 3,000+ S.F. | | | | | A | N | N | 5 | 2 | M8 | | N/C | N/C | N/C | | | |
| | B | | 2,000+ S.F. | | | | A | Y | Y | 2 | 5 | S2 | PLASTER WALL DAMAGE IN BOTH STAIRWAYS UP | N/C | N/C | N/C | | | |
| | | | | | 1500 S.F. | | A | N | N | 5 | 2 | M8 | | N/C | N/C | N/C | | | |
| CORRIDORS TRHOUGHOUT | B-2 | | | | X | | A | N | N | 5 | 2 | M8 | | N/C | N/C | N/C | | | |
| CLASSROOMS THROUGHOUT | 1-2 | | | | | X | A | N | N | 5 | 2 | M8 | | N/C | N/C | N/C | | | |
| BOILER ROOM | B | | 900 S.F. CEILING | | | | A | N | N | 5 | 2 | M8 | | N/C | N/C | N/C | | | |

Code: N = NO; Y = YES; T = THERMAL; S = SURFACING; M = MISCELLANEOUS
N/C = NO CHANGE; R = REPAIRED; D = DAMAGED